



SECTION

NOTES:

1. Drainage pipe to be installed in selected locations on the gravel trail. See Sheets L-2 and L-3 for specific locations.
2. A maximum grade of 8% shall be attained on the gravel trail, where feasible. If this grade is to be exceeded, it shall not extend more than 30', where there shall be a 5' landing area of maximum grade 3%.
3. Crushed stone and gravel samples shall be provided to and approved by Landscape Architect. Crushed stone shall be a natural brown or reddish brown color only.
4. Gravel shall match existing in color and composition.