



TO THE BOARD OF SELECTMEN OF THE TOWN OF CHARLOTTE, VERMONT

Comes the Green Mountain Power Corporation, your petitioner, and respectfully represents that in order to furnish adequate service to its patrons it is necessary to install three new 40' primary poles, three new secondary poles, guys and wires and replace fifteen existing poles, guys and wires within the town road right of way of Flat Rock Rd in the Town of Charlotte, as shown on attached map. Please note the poles labeled in the pink callout boxes indicate where the new poles will be located. The poles will be 40' poles with 5' of the poles will be in the ground, with only 35' out of the ground.

The goal of this project is to remove the old section of wire between Flat Rock Rd (Pole 14, 1611) and Lanes Ln (Pole 15, 9610) and refeed it from Flat Rock Rd and replace the overhead primary wire with TreeWire in order to reduce the number of outages in the area. We hope to start and finish this project before the camp owners return in May 2024, so that it reduces any road congestion in the area.

The Company further represents that such work will be done in accordance with the plans and specifications attached, and in a manner safe for public travel and subject to the rules thereof. Also, that it is not desirable to make such locations otherwise than shown on the attached plan.

WHEREFORE, your petitioner requests permission from the Board of Selectmen to locate poles guys and wires as aforesaid.

Dated at Colchester, Vermont, this 8th day of March 2024.

GREEN MOUNTAIN POWER CORPORATION

By: Meghan Lawler
Meghan Lawler
Distribution Designer 3/8/2024

APPROVED:

Board of Selectmen

Of the

Town of Charlotte

DATE: _____